

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20171110-E139551  
**Report Reference** E139551-19910724  
**Issue Date** 2017-NOVEMBER-10

**Issued to:** KENCO ENGINEERING CO INC  
PO BOX 470426  
TULSA OK 74147

**This is to certify that  
representative samples of**

AUXILIARY DEVICES FOR USE IN HAZARDOUS  
LOCATIONS

Model 9958 and 9959 proximity switches for use in Class I,  
Groups C and D; Class II, Groups E, F and G hazardous  
locations

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**


UL 1203, Explosion-Proof And Dust-Ignition-Proof Electrical  
Equipment For Use In Hazardous (Classified) Locations  
CSA C22.2 NO. 30-M1986, Explosion-Proof Enclosures For  
Use In Class I Hazardous Locations  
CSA C22.2 NO. 25-1966, Enclosures For Use In Class II,  
Groups E, F And G Hazardous Locations  
UL 508 & CSA C22.2 NO. 14-95, Industrial Control  
Equipment

**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

