



Certificate of Compliance

Certificate: 1115266 **Master Contract:** 151908 (044787_0_000)
Project: 70139396 **Date Issued:** 2017-08-15
Issued to: Kenco Engineering Company
Post Office Drawer 470426
Tulsa, Oklahoma 74147
USA
Attention: Darrell Miller

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Wardell Dumas*
Wardell Dumas

PRODUCTS

CLASS - C321107 - INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus

Model LCM Oil Level Controller; CSA Type 4 enclosure; rated 10.0A and 1/4HP, 125 or 250V ac; 1/2 AMP, 125 V dc; 1/4 AMP, 250V dc, 3 AMPS, 125V ac 'L'

Model KLCM Oil Level Controller; CSA Type 4 enclosure; rated 11A at 277 Vac, 1/3 hp at 125 and 250 Vac, 0.5A at 125 Vdc, 0.25A at 250 Vdc

APPLICABLE REQUIREMENTS

CSA Std C22.2 No 0-M91	-	General Requirements - Canadian Electrical Code, Part II
CAN/CSA-C22.2 No. 14-13	-	Industrial Control Equipment
CAN/CSA-C22.2 No. 94-M91	-	Special Purpose Enclosures

MARKINGS

See Report



Supplement to Certificate of Compliance

Certificate: 1115266

Master Contract: 151908 (044787_0_000)

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
70139396	2017-08-15	Update of report 1115266 to amend descriptive document section of report and update for evaluation to CAN/CSA-C22.2 No. 14-13.
2343174	2010-11-11	Update to report 1115266 to add Viton option O-rings as an option to seal the oil reservoir.
2212510	2009-09-22	Update to report 1115266 to add ground wire to the assembly and fix typos/verbiage throughout the report.
2120240	2009-03-19	Update to Report 1115266 due to a Factory Inspection Report (Dated: Jul 02, '08 Trip # OKN13S) to move the date code/serial number on the label and update the drawings.
1610117	2004-11-16	Update of report to include new model (KLCM) with different switch