


ORDERING INFORMATION			
MODEL NUMBER	TANK MATERIAL	SEAL MATERIAL	SCALE CALIBRATION
15866	CS OR SS	A, B, E, V OR T	SEE TABLE BELOW

EXAMPLE MODEL NUMBER: 15866-SS-V-GPH

SCALE CALIBRATION OPTIONS / DEFINITIONS	MAXIMUM PUMPING RATE/GAUGE VOLUME	SCALE CALIBRATION INCREMENT VALUE
GPH=GALLONS PER HOUR	620	10
LPH=LITERS PER HOUR	2346.95	25
GPD=GALLONS PER DAY	14880	200
LPD=LITERS PER DAY	56326.75	500
GBV=GALLONS BY VOLUME	10.33	0.1
LBV=LITERS BY VOLUME	39.12	0.5

NOTE: GPH/LPH/GPD/LPD SCALES ARE BASED ON A ONE MINUTE TEST.

WETTED PARTS: TANK, SIGHT TUBE AND SIGHT TUBE O-RING SEALS



DIMENSIONAL NOTE:
DIMENSIONS ARE FOR REFERENCE PURPOSES ONLY AND ARE SUBJECT TO CHANGE AT ANY TIME WITHOUT NOTICE.
INFORMATION IS PROPRIETARY TO KENCO ENGINEERING CO.

PART NUMBER AND MATERIAL DESIGNATION:

DRAWING NO.	MODEL NO.	MATERIAL:
C-15866-CS	15866-CS	(CARBON STEEL TANK WITH 316/316L STAINLESS STEEL WETTED PARTS ON SIGHT GAUGE)
C-15866-SS	15866-SS	(316/316L STAINLESS STEEL WETTED PARTS)
C-15866-S6	15866-S6	(316/316L STAINLESS STEEL CONSTRUCTION)

REV.	DATE	BY	CHKD.	ECN	EXPLANATION:
A	05-05-10	DS	PAS	000008	ITEM 6 WAS P-13698; ADDED SHEET 2 OF 2; ADDED 13114-A
B	07-19-19	BRC	DS	000299	UPDATED TO REFLECT CHANGE TO 3000 LB. COUPLING.; ADDED -S6 OPTION

KENCO ENGINEERING COMPANY
TULSA, OKLAHOMA

POT, CALIBRATION (OUTLINE)
MODEL NO. 15866

DATE: 09-28-05	SHEET: 1 OF 2	DRAWING NUMBER
DRN. BY: DS	CHKD. BY: KI	C-15866
SCALE: NONE	REVISION: B	