

MODEL NO .: DRAWING NO.: DESCRIPTION:

NFS-3 C-19312 NFS WITH STANDARD SPRING FOR

FLOW RATES OF 6 OR MORE DROPS

PER MINUTE.

NFS WITH LIGHT SPRING FOR FLOW RATES BETWEEN 3 AND 6 DROPS PER NFS-3L C-19312-L

MINUTE.

NOTE: SWITCH MUST BE MOUNTED TERMINAL END UP WITH A MINIMUM ANGLE OF 20° OFF HORIZONTAL TO PREVENT CONDENSATION AROUND SWITCH CONTACT.

INFORMATION IS PROPRIETARY TO KENCO ENGINEERING CO

						TOLERANCES UNLESS OTHERWISE SPECIFIED
						DECIMAL: ±.005" FRACTIONAL: ±1/64" ANGULAR: ±1/2"
EV.	DATE	BY	CHKD.	ECN	EXPLANATION:	KENCO ENGINEERING COMPANY
Α	02-20-96	TW		N/A	ITEM 9 WAS ZINC PLATED CARBON STEEL	
В	10-15-96	W		N/A	O-RING SEALS AND BACK-UP RING	TULSA, OKLAHOMA
					MATERIAL WAS BUNA-N	SWITCH, NO FLOW
C	03-11-05	RDM		N/A	ITEM 13 P/N WAS A-19332	MODEL NFS-3 / NFS-3L
D	08-30-12	DS	KI	000058	REDRAWN; WAS HAND DWG; ADDED SHEET 2;	MODEL NES-3 / NES-3L
					ADDED NFS-3L; RING TERMINAL WAS 16-14	DATE: 02-05-93 SHEET: 1 OF 2 DRAWING NUMBER
						DRN. BY: RC CHKD. BY:
						SCALE: $1-1/2$ "=1" REVISION: D $\overline{C}-19312-\overline{L}$