



MODEL NO.: DRAWING NO.: DESCRIPTION:

NFS-4 C-19313 NFS WITH STANDARD SPRING FOR

FLOW RATES OF 6 OR MORE DROPS

PER MINUTE.

NFS-4L C-19313-L NFS WITH LIGHT SPRI

NFS WITH LIGHT SPRING FOR FLOW RATES BETWEEN 3 AND 6 DROPS PER

MINUTE.

NOTE: SWITCH MUST BE MOUNTED TERMINAL END UP WITH A MINIMUM ANGLE OF 20° OFF HORIZONTAL TO PREVENT CONDENSATION AROUND SWITCH CONTACT.

INFORMATION IS PROPRIETARY TO KENCO ENGINEERING CO

						DECIMAL: ±.005" FRACTIONAL: ±1/64" ANGULAR: ±1/2"
REV.	DATE	BY	CHKD.	ECN	EXPLANATION:	KENCO ENGINEERING COMPANY
В	10-15-96	TW		N/A	O-RING SEALS AND BACK-UP RING	
					MATERIAL WAS BUNA-N	TULSA, OKLAHOMA
С	03-11-05	RDM		N/A	ITEM 13 P/N WAS A-19332; ITEM 20 P/N	SWITCH, NO FLOW
					WAS P-1951	MODEL NFS-4 / NFS-4L
D	08-30-12	DS	KI		REDRAWN; WAS HAND DWG; ADDED SHEET 2;	, ,
					ADDED NFS-4L; RING TERMINAL WAS 16-14;	DATE: 02-05-93 SHEET: 1 OF 2 DRAWING NUMBER
					ITEM 19 WAS P-19466; REMOVED ITEM 20	
					P-2038	SCALE:1-1/2"=1" REVISION: D C-19313-L