

MODEL NO.: DRAWING NO.: DESCRIPTION:

NFS-7 C-19316 NFS WITH STANDARD SPRING FOR

FLOW RATES OF 6 OR MORE DROPS

PER MINUTE.

NFS-7L C-19316-L NFS WITH LIGHT SPRING FOR FLOW

RATES BETWEEN 3 AND 6 DROPS PER

MINUTE.

NOTE: SWITCH MUST BE MOUNTED TERMINAL END UP WITH A MINIMUM ANGLE OF 20° OFF HORIZONTAL TO PREVENT CONDENSATION AROUND SWITCH CONTACT.

INFORMATION IS PROPRIETARY TO KENCO ENGINEERING CO

						TOLERANCES UNLESS OTHERWISE SPECIFIED
						DECIMAL: ±.005" FRACTIONAL: ±1/64" ANGULAR: ±1/2"
REV.	DATE	BY	CHKD.	ECN	EXPLANATION:	KENCO ENGINEERING COMPANY
Α	02-20-96	TW		N/A	ITEM 9 WAS ZINC PLATED CARBON STEEL	
В	10-14-96	TW		N/A	O-RING SEALS AND BACK-UP RING	TULSA, OKLAHOMA
					MATERIAL WAS BUNA-N	SWITCH, NO FLOW
O	03-11-05	RDM		N/A	ITEM 13 P/N WAS A-19332	MODEL NFS-7 / NFS-7L
О	08-30-12	DS	KI	000058	REDRAWN; WAS HAND DWG; ADDED SHEET 2;	MODEL NFS-// NFS-/L
					ADDED NFS-7L; RING TERMINAL WAS 16-14	DATE: 02-05-93 SHEET: 1 OF 2 DRAWING NUMBER
						DRN. BY: RC CHKD. BY: C-19316
						SCALE:1-1/2"=1" REVISION: D \overline{C} -19316-L