

MODEL NO .: DRAWING NO.: **DESCRIPTION:** 

NFS-9 C - 19317NFS WITH STANDARD SPRING FOR

FLOW RATES OF 6 OR MORE DROPS

PER MINUTE.

NFS WITH LIGHT SPRING FOR FLOW RATES BETWEEN 3 AND 6 DROPS PER NFS-9L C-19317-L

MINUTE.

NOTE: SWITCH MUST BE MOUNTED TERMINAL END UP WITH A MINIMUM ANGLE OF 20° OFF HORIZONTAL TO PREVENT CONDENSATION AROUND SWITCH CONTACT.

INFORMATION IS PROPRIETARY TO KENCO ENGINEERING CO.

						TOLERANCES UNLESS OTHERWISE SPECIFIED DECIMAL: ±.005" FRACTIONAL: ±1/64" ANGULAR: ±1/2"
REV.	DATE	BY	CHKD.	ECN	EXPLANATION:	KENCO ENGINEERING COMPANY
Α	02-20-96	TW		N/A	ITEM 9 WAS ZINC PLATED CARBON STEEL	
В	10-14-96	TW		N/A	O-RING SEALS AND BACK-UP RING	TULSA, OKLAHOMA
					MATERIAL WAS BUNA-N	SWITCH, NO FLOW
С	03-11-05	RDM		N/A	ITEM 13 P/N WAS A-19332	MODEL NFS-9 / NFS-9L
D	08-30-12	DS	KI	000058	REDRAWN; WAS HAND DWG; ADDED SHEET 2;	MODEL NES-8 / NES-8F
					ADDED NFS-9L; RING TERMINAL WAS 16-14	DATE: 02-05-93 SHEET: 1 OF 2 DRAWING NUMBER
						DRN. BY: RC   CHKD. BY:   C-19317
						SCALE: $1-1/2$ "=1" REVISION: D $C-19317-L$