

**ORDERING INFORMATION**



MODEL NUMBER	TANK MATERIAL	SEAL MATERIAL	SCALE CALIBRATION
15847	CS OR SS	A, B, E, V OR T	SEE TABLE BELOW

EXAMPLE MODEL NUMBER: 15847-SS-V-GPH

SCALE CALIBRATION OPTIONS / DEFINITIONS	MAXIMUM PUMPING RATE/GAUGE VOLUME	SCALE CALIBRATION INCREMENT VALUE
GPH=GALLONS PER HOUR	10	0.2
LPH=LITERS PER HOUR	37.85	0.5
GPD=GALLONS PER DAY	240	5
LPD=LITERS PER DAY	908.5	10
GBV=GALLONS BY VOLUME	0.17	0.002
LBV=LITERS BY VOLUME	0.63	0.01

NOTE: GPH/LPH/GPD/LPD SCALES ARE BASED ON A ONE MINUTE TEST.

WETTED PARTS: TANK, SIGHT TUBE AND SIGHT TUBE O-RING SEALS



DIMENSIONAL NOTE:  
DIMENSIONS ARE FOR REFERENCE  
PURPOSES ONLY AND ARE SUBJECT TO  
CHANGE AT ANY TIME WITHOUT NOTICE.

INFORMATION IS PROPRIETARY TO KENCO ENGINEERING CO.

**PART NUMBER AND MATERIAL DESIGNATION:**

DRAWING NO.	MODEL NO.	MATERIAL:
C-15847-CS	15847-CS	(CARBON STEEL TANK WITH 316/316L STAINLESS STEEL WETTED PARTS ON SIGHT GAUGE)
C-15847-SS	15847-SS	(316/316L STAINLESS STEEL CONSTRUCTION)

REV.	DATE	BY	CHKD.	ECN	EXPLANATION:
A	06-03-93	RC	-	-	ITEM 4 P/N WAS B-14109
B	12-14-94	RC	-	-	ITEM 4 P/N WAS A-18954, MAT'L WAS 6061-T6 ALUM.
C	06-24-05	DS	KI	-	ITEM 1 P/N WAS C-15867
D	05-03-10	DS	PAS	000008	REDRAWN; WAS HAND DWG.; ITEM 2 DESCRIPTION WAS PYREX GAUGE GLASS ITEM 6 WAS P-13698; ADDED SHEET 2 OF 2; ADDED 13114-A

**KENCO ENGINEERING COMPANY**  
TULSA, OKLAHOMA

POT, CALIBRATION (OUTLINE)  
MODEL NO. 15847

DATE: 11-15-91	SHEET: 1 OF 2	DRAWING NUMBER
DRN. BY: RC	CHKD. BY:	C-15847
SCALE: NONE	REVISION: D	