


ORDERING INFORMATION			
MODEL NUMBER	TANK MATERIAL	SEAL MATERIAL	SCALE CALIBRATION
15853	CS OR SS	A, B, E, V OR T	SEE TABLE BELOW

EXAMPLE MODEL NUMBER: 15853-SS-V-GPH

SCALE CALIBRATION OPTIONS / DEFINITIONS	MAXIMUM PUMPING RATE/GAUGE VOLUME	SCALE CALIBRATION INCREMENT VALUE
GPH=GALLONS PER HOUR	60	1
LPH=LITERS PER HOUR	227.12	5
GPD=GALLONS PER DAY	1440	25
LPD=LITERS PER DAY	5450.98	100
GBV=GALLONS BY VOLUME	1	0.02
LBV=LITERS BY VOLUME	3.79	0.05

NOTE: GPH/LPH/GPD/LPD SCALES ARE BASED ON A ONE MINUTE TEST.
WETTED PARTS: TANK, SIGHT TUBE AND SIGHT TUBE O-RING SEALS



PART NUMBER AND MATERIAL DESIGNATION:

DRAWING NO. MODEL NO. MATERIAL:
 C-15853-CS 15853-CS (CARBON STEEL TANK WITH 316/316L STAINLESS STEEL WETTED PARTS ON SIGHT GAUGE)
 C-15853-SS 15853-SS (316/316L STAINLESS STEEL CONSTRUCTION)

DIMENSIONAL NOTE:
 DIMENSIONS ARE FOR REFERENCE PURPOSES ONLY AND ARE SUBJECT TO CHANGE AT ANY TIME WITHOUT NOTICE.
 INFORMATION IS PROPRIETARY TO KENCO ENGINEERING CO.

REV.	DATE	BY	CHKD.	ECN	EXPLANATION:	KENCO ENGINEERING COMPANY TULSA, OKLAHOMA
A	06-03-93	RC	-	-	ITEM 4 P/N WAS B-14109	
B	12-14-94	RC	-	-	ITEM 4 P/N WAS A-18954, MAT'L WAS 6061-T6 ALUM.	
C	05-05-10	DS	PAS	000008	REDRAWN; WAS HAND DWG.; ITEM 2 DESCRIPTION WAS PYREX GAUGE GLASS	DATE: 11-15-91 SHEET: 1 OF 2 DRAWING NUMBER DRN. BY: RC CHKD. BY: C-15853 SCALE: NONE REVISION: c
					ITEM 6 WAS P-13698; ADDED SHEET 2 OF 2; ADDED 13114-A	