



ORDERING INFORMATION

MODEL NUMBER	TANK MATERIAL	SEAL MATERIAL	SCALE CALIBRATION
15857	CS OR SS	A, B, E, V OR T	SEE TABLE BELOW

EXAMPLE MODEL NUMBER: 15857-SS-V-GPH

SCALE CALIBRATION OPTIONS / DEFINITIONS	MAXIMUM PUMPING RATE/GAUGE VOLUME	SCALE CALIBRATION INCREMENT VALUE
GPH=GALLONS PER HOUR	100	2
LPH=LITERS PER HOUR	378.54	5
GPD=GALLONS PER DAY	2400	25
LPD=LITERS PER DAY	9084.96	100
GBV=GALLONS BY VOLUME	1.67	0.02
LBV=LITERS BY VOLUME	6.31	0.1

NOTE: GPH/LPH/GPD/LPD SCALES ARE BASED ON A ONE MINUTE TEST.
WETTED PARTS: TANK, SIGHT TUBE AND SIGHT TUBE O-RING SEALS

DIMENSIONAL NOTE:
DIMENSIONS ARE FOR REFERENCE
PURPOSES ONLY AND ARE SUBJECT TO
CHANGE AT ANY TIME WITHOUT NOTICE.

INFORMATION IS PROPRIETARY TO KENCO ENGINEERING CO.

PART NUMBER AND MATERIAL DESIGNATION:

DRAWING NO. MODEL NO. MATERIAL:
 C-15857-CS 15857-CS (CARBON STEEL TANK WITH 316/316L
 STAINLESS STEEL WETTED PARTS ON SIGHT GAUGE)
 C-15857-SS 15857-SS (316/316L STAINLESS STEEL CONSTRUCTION)

REV.	DATE	BY	CHKD.	ECN	EXPLANATION:
A	06-03-93	RC	-	-	ITEM 4 P/N WAS B-14109
B	12-14-94	RC	-	-	ITEM 4 P/N WAS A-18954, MAT'L WAS 6061-T6 ALUM.
C	01-02-07	DS	-	-	REDRAWN; WAS HAND DWG.; ITEM 2 DESCRIPTION WAS PYREX GAUGE GLASS
D	05-03-10	DS	PAS	000008	ITEM 6 WAS P-13698; ADDED SHEET 2 OF 2; ADDED 13114-A

KENCO ENGINEERING COMPANY
TULSA, OKLAHOMA

POT, CALIBRATION (OUTLINE)
MODEL NO. 15857

DATE: 11-15-91	SHEET: 1 OF 2	DRAWING NUMBER
DRN. BY: RC	CHKD. BY:	C-15857
SCALE: NONE	REVISION: D	