



ORDERING INFORMATION			
MODEL NUMBER	TANK MATERIAL	SEAL MATERIAL	SCALE CALIBRATION
15861	CS OR SS	A, B, E, V OR T	SEE TABLE BELOW

EXAMPLE MODEL NUMBER: 15861-SS-V-GPH

SCALE CALIBRATION OPTIONS / DEFINITIONS	MAXIMUM PUMPING RATE/GAUGE VOLUME	SCALE CALIBRATION INCREMENT VALUE
GPH=GALLONS PER HOUR	140	2
LPH=LITERS PER HOUR	529.96	10
GPD=GALLONS PER DAY	3360	50
LPD=LITERS PER DAY	12,718.94	200
GBV=GALLONS BY VOLUME	2.33	0.05
LBV=LITERS BY VOLUME	8.83	0.1

NOTE: GPH/LPH/GPD/LPD SCALES ARE BASED ON A ONE MINUTE TEST.

WETTED PARTS: TANK, SIGHT TUBE AND SIGHT TUBE O-RING SEALS

DIMENSIONAL NOTE:
DIMENSIONS ARE FOR REFERENCE
PURPOSES ONLY AND ARE SUBJECT TO
CHANGE AT ANY TIME WITHOUT NOTICE.

INFORMATION IS PROPRIETARY TO KENCO ENGINEERING CO.

PART NUMBER AND MATERIAL DESIGNATION:

DRAWING NO. MODEL NO. MATERIAL:
 C-15861-CS 15861-CS (CARBON STEEL TANK WITH 316/316L
 STAINLESS STEEL WETTED PARTS ON SIGHT GAUGE)
 C-15861-SS 15861-SS (316/316L STAINLESS STEEL CONSTRUCTION)

REV.	DATE	BY	CHKD.	ECN	EXPLANATION:	KENCO ENGINEERING COMPANY TULSA, OKLAHOMA	POT, CALIBRATION (OUTLINE) MODEL NO. 15861
A	06-03-93	RC	-	-	ITEM 4 P/N WAS B-14109		
B	12-14-94	RC	-	-	ITEM 4 P/N WAS A-18954, MAT'L WAS 6061-T6 ALUM.	DRAWING NUMBER C-15861	
C	01-02-07	DS	-	-	REDRAWN; WAS HAND DWG.; ITEM 2 DESCRIPTION WAS PYREX GAUGE GLASS		
D	05-05-10	DS	PAS	000008	ITEM 6 WAS P-13698; ADDED SHEET 2 OF 2; ADDED 13114-A		