


ORDERING INFORMATION			
MODEL NUMBER	TANK MATERIAL	SEAL MATERIAL	SCALE CALIBRATION
15863	CS OR SS	A, B, E, V OR T	SEE TABLE BELOW

EXAMPLE MODEL NUMBER: 15863-SS-V-GPH

SCALE CALIBRATION OPTIONS / DEFINITIONS	MAXIMUM PUMPING RATE/GAUGE VOLUME	SCALE CALIBRATION INCREMENT VALUE
GPH=GALLONS PER HOUR	280	5
LPH=LITERS PER HOUR	1059.91	10
GPD=GALLONS PER DAY	6720	100
LPD=LITERS PER DAY	25437.89	250
GBV=GALLONS BY VOLUME	4.67	0.05
LBV=LITERS BY VOLUME	17.67	0.2

NOTE: GPH/LPH/GPD/LPD SCALES ARE BASED ON A ONE MINUTE TEST.

WETTED PARTS: TANK, SIGHT TUBE AND SIGHT TUBE O-RING SEALS



DIMENSIONAL NOTE:
DIMENSIONS ARE FOR REFERENCE
PURPOSES ONLY AND ARE SUBJECT TO
CHANGE AT ANY TIME WITHOUT NOTICE.

COPYRIGHT © 2005-KENCO INTERNATIONAL, INC.-ALL RIGHTS RESERVED

PART NUMBER AND MATERIAL DESIGNATION:

DRAWING NO. MODEL NO. MATERIAL:
 C-15863-CS 15863-CS (CARBON STEEL TANK WITH 316/316L
 STAINLESS STEEL WETTED PARTS ON SIGHT GAUGE)
 C-15863-SS 15863-SS (316/316L STAINLESS STEEL CONSTRUCTION)

REV.	DATE	BY	CHKD.	ECN	EXPLANATION:
A	05-05-10	DS	PAS	000008	ITEM 6 WAS P-13698; ADDED SHEET 2 OF 2; ADDED 13114-A

KENCO ENGINEERING COMPANY
TULSA, OKLAHOMA

POT, CALIBRATION (OUTLINE)
MODEL NO. 15863

DATE: 09-27-05	SHEET: 1 OF 2	DRAWING NUMBER
DRN. BY: DS	CHKD. BY: KI	C-15863
SCALE: NONE	REVISION: A	