



RATE / VOLUME

| SCALE CALIBRATION (UNITS OF MEASURE) | MAXIMUM RATE/VOLUME | SCALE CALIBRATION (DIVISION INCREMENTS) |
|---|------------------------|--|
| * GALLONS PER HOUR | 2.50 | 0.05 |
| * LITERS PER HOUR | 9.46 | 0.20 |
| * GALLONS PER DAY | 60.00 | 1.00 |
| * LITERS PER DAY | 227.12 | 5.00 |
| GALLONS BY VOLUME | 0.04 | 0.001 |
| LITERS BY VOLUME | 0.16 | 0.005 |

* RATE SCALE CALIBRATIONS ARE BASED ON A 1 MINUTE TEST



MODEL 30060-CS MODEL 30060-S4/S6

DIMENSION ARE FOR REFERENCE PURPOSES ONLY AND ARE
SUBJECT TO CHANGE AT ANY TIME WITHOUT NOTICE.

COPYRIGHT © 2003 KENCO INTERNATIONAL, INC.-ALL RIGHTS RESERVED

| REV. | DATE | BY | ECN | EXPLANATION: | KENCO ENGINEERING COMPANY TULSA, OKLAHOMA | | |
|------|------|----|-----|--------------|---|---------------|----------------|
| | | | | | GAUGE, PUMP SETTING (OUTLINE DRAWING) MODEL 30060-CS/S4/S6 | | |
| | | | | | DATE: 01-31-03 | SHEET: 1 OF 1 | DRAWING NUMBER |
| | | | | | DRN. BY: DPS | CHKD. BY: | |
| | | | | | SCALE: NONE | REVISION: | C-43554 |