



Certificate of Compliance

Certificate: 2624715

Master Contract: 151908

Project: 2624715

Date Issued: May 23, 2013

Issued to: Kenco Engineering Company

Post Office Drawer 470426

Tulsa, OK 74147

USA

Attention: David Ragland

*The products listed below are eligible to bear the
CSA Mark shown with adjacent indicator 'NRTL/C'*



Jelena Dzeletovic

Issued by: Jelena Dzeletovic

PRODUCTS

CLASS 3218 86 - INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus - For Hazardous Locations-Certified to U.S. Standards

CLASS 3218 06 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus - For Hazardous Locations

Class I, Groups A, B, C and D; Class II, Groups E, F and G; Class III:

Proximity Switch Cat No. 25654, contact rated 200 Vac or dc, 500mA, 10W max; Max. Ambient 105 Deg. C; Type 4, Temperature Code T4A.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 14-10 - Industrial Control Equipment

CSA Std C22.2 No. 30-M1986 (R 2012) - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

CSA STD C22.2 No. 94 M91(R2011) - Special Purpose Enclosures



Certificate: 2624715

Master Contract: 151908

Project: 2624715

Date Issued: May 23, 2013

UL Std No. 508 (17th Edition) - Industrial Control Equipment

UL Std No. 886 - 94 - Outlet Boxes and Fittings for Use in Hazardous (Classified) Locations

UL Std No. 50 - 95 - Enclosures for Electrical Equipment, Non-Environmental Consideration